

**PFAS TEST RESULTS**  
**MAHONING VALLEY SANITARY DISTRICT**

PFAS Compound	Statewide Action Level (ng/L)	Your PWS
		EP001 Treated Water (ng/L)
PFOA	>70 single or combined with PFOS	<5
PFOS	>70 single or combined with PFOA	<b>12.9</b>
GenX	>700	<25
PFBS	>140,000	<5
PFHxS	>140	<b>5.42</b>
PFNA	>21	<5

**These results indicate you have at least one PFAS present in finished water above the reporting level and follow-up monitoring will continue for at least one year from the date of your initial detection.**