

Analyses	Base Test Taken 11/14/13	Units	Results for 3/2/22	Results for 4/29/22
Conductivity	460	umhos/cm	557	382
pH	7.56	ph Units	6.12	8.17
Total Dissolved Solids	310	mg/l	371	254
Total Suspended Solids	2.0	mg/l	<1.00	5
Oil and Grease	ND	mg/l	<4.00	<5.88
Turbidity	2.5	NTU		
Manganese	88	ug/l	16.0	<20.0
Barium	ND	ug/l	15.6	<100
Calcium	29	mg/l	34.3	26.6
Chromium	ND	ug/l	<1.00	1.23
Iron	ND	ug/l	180	235
Magnesium	11	mg/l	9.20	7.24
Sodium	48	mg/l	22.7	35.90
Strontium	130	ug/l	80.6	<100
Potassium	4.7	mg/l	3.22	3.35
Arsenic	ND	ug/l	<1	1.57
Lead	ND	ug/l	<5.00	<5.00
Selenium	ND	ug/l	<1.00	1.35
Alkalinity	70	mg/l	70.0	50.0
Chloride	66	mg/l	80	55.0
Sulfate	95	mg/l	42.3	38.8
MBAS	ND	mg/l	<1.00	<1.00
Xylene, Total	710	ug/l	<0.500	<0.500
Benzene	ND	ug/l	<.500	<0.500
Toluene	ND	ug/l	<.500	<0.500
Ethylbenzene	ND	ug/l	<.500	<0.500
Bromide	<0.2	mg/l	<0.500	<0.100
Nitrates	ND	mg/l	0.590	0.356
Methane	ND	mg/l	<0.0100	<0.0100
Hardness	120	mg/l	123	96.2