

**ADDENDUM NO. 1 - (A)
CONTRACT NO. M-612
FOR FURNISHING POWDER ACTIVATED CARBON FOR
THE MAHONING VALLEY SANITARY DISTRICT
OCTOBER 10, 2024**

CLARIFYING QUESTIONS - CORRECTION NO. 4

1. **What was the total PAC usage in the last 12 months?**
A: For the year 2023 188 tons of PAC was used
2. **Why was the minimum iodine changed to be 500?**
A: To permit flexibility to bidders
3. **Will the bid prices be adjusted to account for performance?**
A: Yes. See Section 1.0, IB-13 on page 5 and Section 5, Subsection 9 on page 20
4. **What is the typical order quantity for PAC?**
A: Approximately 45,000-lbs. See Section 5, Subsection (SHOULD BE SUBSECTION 5 NOT 15) on page 19
5. **How long are the prices submitted valid for?**
A: The contract period is January 1st 2025 to December 31st 2025, see page 7

ATTENTION

Proposers are, therefore, instructed to take the following into account in rendering any Proposal for this work.

Item 1: CLARIFYING RESPONSES

END OF ADDENDUM NO. 1